



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
TTY: Contact Through Relay

Jim Doyle, Governor  
Richard J. Leinenkugel, Secretary

December 17, 2009

DEPARTMENT OF COMMERCE  
SAFETY AND BUILDINGS  
TOM BRAUN  
201 W WASHINGTON AVE.  
PO BOX P.O. BOX 7162  
MADISON WI 53701-7162

Re: Description: ALTERNATE SYSTEM  
Manufacturer: DEPARTMENT OF COMMERCE  
Product Name: USE OF WATER CLOSET OR LAVATORY AS RECEPTOR OF INDIRECT WASTE FROM  
DIALYSIS APPLIANCE AND DIALYSIS WATER TREATMENT DEVICE  
Model Number(s): NONE  
Product File No: 20090418

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.33 (8) (d) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This approval applies to a water closet or lavatory located in a patient toilet room of single occupancy in a health care facility.
- The discharge to the plumbing fixtures shall be made by either a temporary or permanent fixed 1" air-gap that will not impede normal operation of the fixture when not in dialysis mode.
- The discharge to the fixtures shall be limited to a department approved portable healthcare dialysis appliance and a portable water treatment device specifically for dialysis use.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Thomas Braun  
Plumbing Consultant  
PHONE: 715-340-5387  
FAX: 608-283-0000  
email: thomas.braun@wisconsin.gov